

SAINT MARYS
WV3303704
Consumer Confidence Report – 2024
Covering Calendar Year – 2023

This brochure is a snapshot of the quality of the water that we provided last year. Included are the details about where your water comes from, what it contains, and how it compares to Environmental Protection Agency (EPA) and state standards. We are committed to providing you with information because informed customers are our best allies. If you would like to observe the decision-making process that affects drinking water quality or if you have any questions, comments, or suggestions, please attend any regularly scheduled water board meeting held on the first and third Tuesday of each month at 7:00 P.M. Est in the *City Hall of St. Marys, WV located at 418 Second Street St. Marys, WV 26170* or call L. PAUL INGRAM at 304-684-2401.

Your water comes from Ground water:

Source Name	Source Water Type
WELL NO. 7	Ground water
WELL NO. 5	Ground water
WELL NO. 6	Ground water

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as those with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (800-426-4791).

The sources of drinking water (both tap water and bottled water) included rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in sources water before we treat it include:

Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, livestock operations and wildlife.

Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.

Pesticides and herbicides, which may come from a variety of sources such as storm water run-off, agriculture, and residential users.

Radioactive contaminants, which can be naturally occurring or the result of mining activity.

Organic contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and also come from gas stations, urban storm water run-off, and septic systems.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limits the amount of certain contaminants in water provided by public water systems. We treat our water according to EPA's regulations. Food and Drug Administration regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

Our water system has an estimated population of 2711 and is required to test a minimum of 3 sample(s) per month in accordance with the Total Coliform Rule for microbiological contaminants. Coliform bacteria are usually harmless, but their presence in water can be an indication of disease-causing bacteria. When coliform bacteria are found, special follow-up tests are done to determine if harmful bacteria are present in the water supply. If this limit is exceeded, the water supplier must notify the public.

Water Quality Data

The following tables list all of the drinking water contaminants which were detected during the 2023 calendar year. The presence of these contaminants does not necessarily indicate the water poses a health risk. Unless noted, the data presented in this table is from the testing done January 1- December 31, 2023. The state requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of the data, though representative of the water quality, is more than one year old.

Terms & Abbreviations

Maximum Contaminant Level Goal (MCLG): the "Goal" is the level of a contaminant in drinking water below which there is no known or expected risk to human health. MCLGs allow for a margin of safety.

Maximum Contaminant Level (MCL): the "Maximum Allowed" is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Secondary Maximum Contaminant Level (SMCL): recommended level for a contaminant that is not regulated and has no MCL.

Action Level (AL): the concentration of a contaminant that, if exceeded, triggers treatment or other requirements.

Treatment Technique (TT): a required process intended to reduce levels of a contaminant in drinking water.

Maximum Residual Disinfectant Level (MRDL): the highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Non-Detects (ND): lab analysis indicates that the contaminant is not present.

Parts per Million (ppm): or milligrams per liter (mg/L)

Parts per Billion (ppb): or micrograms per liter (µg/L)

Picocuries per Liter (pCi/L): a measure of the radioactivity in water.

Millirems per Year (mrem/yr): measure of radiation absorbed by the body.

Monitoring Period Average (MPA): An average of sample results obtained during a defined time frame, common examples of monitoring periods are monthly, quarterly and yearly.

Nephelometric Turbidity Unit (NTU): a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person. Turbidity is not regulated for groundwater systems.

Running Annual Average (RAA): an average of sample results obtained over the most current 12 months and used to determine compliance with MCLs.

Locational Running Annual Average (LRAA): Average of sample analytical results for samples taken at a particular monitoring location during the previous four calendar quarters.

Testing Results for: SAINT MARYS

Regulated Contaminants	Collection Date	Highest Value	Range (low/high)	Unit	MCL	MCLG	Typical Source
BARIUM	12/28/2022	0.0626	0.0626	ppm	2	2	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
CHROMIUM	12/28/2022	2.3	2.3	ppb	100	100	Discharge from steel and pulp mills; Erosion of natural deposits
FLUORIDE	12/28/2022	0.66	0.66	ppm	4	4	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
NITRATE	11/21/2023	2.3	2.2 - 2.3	ppm	10	10	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
NITRATE-NITRITE	12/28/2022	3.2	3.2	ppm	10	10	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits

Disinfection Byproducts	Sample Point	Collection Date	Highest Value	Range (low/high)	Unit	MCL	MCLG	Typical Source
TTHM	837 FISH POT ROAD	2023	1	1 - 1	ppb	80	0	By-product of drinking water chlorination

Lead and Copper	Monitoring Period	90TH Percentile	Range (low/high)	Unit	AL	Sites Over AL	Typical Source
COPPER, FREE	2020 - 2022	0.579	0.0602 - 0.657	ppm	1.3	0	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
LEAD	2020 - 2022	0.46	0.13 - 0.48	ppb	15	0	Corrosion of household plumbing systems; Erosion of natural deposits

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Your water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

SAINT MARYS is working towards identifying service line materials throughout the water distribution supply. The service line inventory is required to be submitted to the state by October 16, 2024. The most up to date inventory is located at *City Hall of St. Marys, WV located at 418 Second Street St. Marys, WV 26170* or call L. PAUL INGRAM at 304-684-2401, if you have any questions about our inventory, please contact, L. PAUL INGRAM at 304-684-2401.

Chlorine/Chloramines Maximum Disinfection Level	MPA	MPA Units	RAA	RAA Units
4/1/2023 - 4/30/2023	0.73000	MG/L	0.70000	MG/L

Radiological Contaminants	Collection Date	Highest Value	Range	Unit	MCL	MCLG	Typical Source
COMBINED URANIUM	12/28/2022	0.053	0.053	µg/L	30	0	Erosion of natural deposits
GROSS ALPHA, EXCL. RADON & U	12/28/2022	0.548	0.548	pCi/L	15	0	Erosion of natural deposits
GROSS BETA PARTICLE ACTIVITY	12/28/2022	1.94	1.94	pCi/L	0	0	Decay of natural and man-made deposits. Note: The gross beta particle activity MCL is 4 millirems/year annual dose equivalent to the total body or any internal organ. 50 pCi/L is used as a screening level.

Secondary Contaminants-Non Health Based Contaminants-No Federal Maximum Contaminant Level (MCL) Established.	Collection Date	Highest Value	Range (low/high)	Unit	SMCL
NICKEL	12/28/2022	0.00055	0.00055	MG/L	0.1
SODIUM	12/28/2022	22.4	22.4	MG/L	1000

During the 2023 calendar year, we had the below noted violation(s) of drinking water regulations.

Compliance Period	Analyte	Comments
No violations occurred in the calendar year 2023		

Additional Required Health Effects Language:

Certain minerals are radioactive and may emit forms of radiation known as photons and beta radiation. Some people who drink water containing beta particle and photon radioactivity in excess of the MCL over many years may have an increased risk of getting cancer.

There are no additional required health effects violation notices.

This document will not be mailed.
To receive a paper copy in the mail, please contact us at the phone number above.

CCR CERTIFICATION - FORMAT FOR SYSTEMS WITH MAILING WAIVERS

*Complete only the sections that apply to the method of notification to your customers.
Fill in completely: CWS Name, PWS ID#, method of notification, and certified by.*

CWS NAME; City of St. Marys

PWS ID#: W.V. 3303704

I confirm that the Consumer Confidence Report (CCR) has been distributed to customers or published with appropriate notices of availability and that the information is correct and consistent with the compliance monitoring data previously submitted to the primacy agency.

SYSTEMS SERVING 501 to 10,000 PERSONS [e.g., DID NOT MAIL, USED NEWS PAPER(S)]. Must complete both parts of this section.

 Published the CCR in the local newspaper(s). ATTACH A COPY OF THE NEWSPAPER NOTICE(S) TO THIS FORM. List the newspaper(s) and dates of publication below.

 Informed customers that the CCR would not be mailed. [List method(s) below. This is usually done by a disclaimer at the bottom of the newspaper notification(s). e.g., "This Consumer Confidence Report will not be mailed to you."]

OR

SYSTEMS SERVING 501 to 10,000 PERSONS (e.g., MAILED CCR, DIRECT DELIVERY, PLACED COMPLETE CCR WITH/ON WATER BILL, OR OTHER).

CCR was distributed by mail, direct delivery or other methods. [Specify which method(s) was used].

2024 CCR WILL BE ON OUR WATERBILL (DIRECT URL LINK)

ATTACHED IS A COPY. HAS BEEN APPROVED BY THE STATE

CCR was distributed by e-mail and/or a dedicated URL link

Certified By: Name (Print): MATTHEW BURWELL

Title: CHIEF WATER OPERATOR

Phone # 304-684-2401 Date: 08/07/2024

Karen

Please find below our direct link to the CCR reports on the City of St. Marys' website.

<https://stmarys.wv.gov/SiteCollectionDocuments/2022%20CCR.pdf>